Amendment No. 01 to the Bidding Document

SUPPLY, INSTALLATION & COMMISSIONING OF TWO NO(S). OF DIESEL GENERATING SETS WITH PRIME RATING OF 200KVA & 300KVA WITH ALLIED ACCESSORIES AT FPCCI CAPITAL HOUSE ISLAMABAD.

Procurement No. FPCCI/DG/2025/01

With reference to the bidding documents for the subject tender, the following provisions/clauses are hereby amended as under:-

Sr. #	Clause #	Page #	Existing Text	Revised Text	
1.	Section-III (Bid Data Sheet)- Clause 13.3 (b) (i)	BDS-6	 Contract/Performance Requirements Experience The offered Manufacturer should have manufacturing experience of similar or higher rating goods for past 15 years with at least Five (5) years of operational experience to be ascertained by operational certificate (03 Nos.) issued by the end users (Pakistan based end-users) in favor of the manufacturer. 	operational experience to be ascertained by operational certificate (03 Nos.) issued by the end users	
2.	Section-III (Bid Data Sheet)- Clause 8 - 3.5 - b	BDS-2	The Bidder shall be manufacturer or Supplier legally registered for at least Fifteen (15) years. A copy of legal registration certificate shall be submitted along with the Bid.	The Bidder shall be manufacturer or Supplier legally registered for at least Ten (10) years. A copy of legal registration certificate shall be submitted along with the Bid.	

3.	Section-III	BDS-9	The amount of Bid Security shall be PKR: 02	The amount of Bid Security shall be PKR: 1
	(Bid Data		Million	Million
	Sheet)- Clause		The currency of the Bid Security shall be: PKR	The currency of the Bid Security shall be: PKR
	39- 18.1			
4.	4. Section-III BDS-11		Bid Submission Day/Date & Time: 24 th Sept	Bid Submission Day/Date & Time 07 th
	(Bid Data		2025 at 03:00 PM	October 2025 at 03:00 PM
	Sheet)- Clause			
	22.2(b), 23.1 &			
	26.1		Bid Opening Day/Date & Time: 24 th Sept	Bid Opening Day/Date & Time: 07 th October
			2025 at 04:00 PM	2025 at 04:00 PM
5.	Section-V	SP-02	Sync Panel = 02	Sync Panel = 01
	(Schedule of		ATS Panel = 02	ATS Panel = 01
	Requirements,			
	Technical			
	Specifications)			
	- Clause SP-			
	01.1			
6.	Section-V	SP-02	Performance Class of Genset should be G3	Performance Class of Genset should be G2 &
	(Schedule of		(equivalent) or higher.	G3 (equivalent) or higher.
	Requirements,			For:
	Technical		200kVA G3 Class	200kVA G2 Class
	Specifications)		300kVA G3 Class	300kVA G3 Class
	– Clause SP-02			

7.	Section-V	SP-04	Rating of Power Cable from Sync Panel to Ats	Power Cable From 200kVA to the Sync Panel
	(Schedule of		Panel:	Should be 120mm.sq Single Core and
	Requirements,		Power Cable .240 mm.sq Single Core Copper	185mm.sq for 300kVA. After synchronization
	Technical			of both gensets, the 240mm.sq is required
	Specifications)			from Sync. Panel to the ATS Panel.
	Clause- SP-02			
	SPECIFICATIONS			

Note:

- i) The above listed changes shall apply to the extent specified in this Amendment and shall prevail in case of any contradiction in the bidding document to the extent specified above.
- ii) All of the remaining provisions shall remain same/unchanged and applicable.

FOLLOWING AMENDEMENTS ARE MADE IN BIDDING DOCUMENT:

28. 13.3 (b) (i)	 The offered Manufacturer should have manufacturing experience of similar or higher rating goods for past 10 years with at least Five (5) years of operational experience to be ascertained by operational certificate (03 Nos.) issued by the end users (Pakistan based end-users) in favor of the manufacturer.
-------------------------	--

8.	3.5	b) The Bidder shall be manufacturer or Supplier legally registered for at least Ten (10) years. A copy of legal registration certificate shall be submitted along with the Bid.
		The amount of Bid Security shall be PKR: 1 Million The currency of the Bid Security shall be: PKR

Sr.	Description	UOM	Qty
No.			
1	Supply of 200 kVA Diesel Generators , RPM 1500, Frequency 50 Hz, Class G2	Nos.	1
2	Supply of 300 kVA Diesel Generators , RPM 1500, Frequency 50 Hz, Class G3	Nos.	1
3	Canopies 85 dBA at 1 Meter	Nos.	2
4	Bulk Fuel Tank 2000 Liters	Nos.	1
5	Sync Panel	Nos.	1
6	ATS Panel, 3 Pole with accessories	Nos.	1
	Sync & ATS Panel Base Stand	Nos.	1
7	WAPDA Incoming Breaker, 630 Amp, 3 Pole	Nos.	1
8	Earthing of System	Nos.	6
9	Earthing Cables	Lot	1
10	Control Cables	Lot	1
11	Power Cables	Lot	1
12	Installation of Gen Sest, Main Incoming Panel, ATS & Sync	Lot	1
13	Transportation	Lot	1
14	Commissioning of Units	Lot	1

		·
g.		Power Cable Power Cable From 200kVA to the Sync
	Cables	Panel Should be 120mm.sq Single Core and 185mm.sq for
	Cables	300kVA. After synchronization of both gensets, the
		240mm.sq Copper PVC/PVC is required from Sync. Panel

THE FEDERATION OF PAKISTAN CHAMBERS OF COMMERCE & INDUSTRY

Amendment No. 01 to the Tender Notice SUPPLY, INSTALLATION & COMMISSIONING OF TWO NO(S). OF DIESEL GENERATING SETS WITH PRIME RATING OF 200KVA & 300KVA WITH ALLIED ACCESSORIES AT FPCCI CAPITAL HOUSE ISLAMABAD.

Procurement No. FPCCI/DG/2025/01

With reference to the notice for Invitation for (E-BIDs) <u>Dated **04-09-2025**</u>, published in Roznama/Daily "Nawai-Waqt" and "The Nation", it is hereby notified that the bids submission date (through EPADs) is hereby extended till Dated: **07-10-2025**, **Time: 3PM PST** instead of existing i.e.,24th September 2025. The Technical bids will be opened on the same day at 04:00 PM PST.

DIRECTOR ADMINISTRATION

FPCCI Capital House, G-8/1, Aiwan— e— Sanat—o—Tijarat Road, Mauve Area, Islamabad Tel: +92-51-2251891-3; +92-51-2289303 Email: islamabad.capital@fpcci.org.pk

CLARIFICATION RESPONSE # 1 FOR THE SUPPLY, INSTALLATION & COMMISSIONING OF TWO NO(S). OF DIESEL GENERATING SETS WITH PRIME RATING OF 200KVA & 300KVA WITH ALLIED ACCESSORIES AT FPCCI CAPITAL HOUSE ISLAMABAD Procurement No. FPCCI/DG/2025/01

Bidder's Queries	Response		
Relaxation in Eligibility criteria	Please refer to Amendment No. 01 to the Bidding Document.		
Relation of Bid Security requirement	Please refer to Amendment No. 01 to the Bidding Document.		
Please clarify that combination of G2 and G3 Gensets will be acceptable?	Working solution with a combination of G2 and G3 class is acceptable to take up load capability. For: 200kVA – G2 Class,300kVA – G3 Class		
G.C.C Clause # 19 Section 9.1: We suggest to please allow the release of second milestone payment which is 40% after successful inspection of the units at Manufacturers factory outside Pakistan and at proof of shipment/bill of lading against submission of un-conditional Bank Guarantee from AAA rated bank to safeguard FPCCI money.	Please follow the provisions of the bidding document.		
Pre Shipment Inspection	 Pursuant to Section-VIII: 11.2 & 11.5, the testing scheme is hereby clarified as under:- The bidder has to accommodate 02 inspectors at manufacturer premises in which units shall be physically inspected at manufacturer's premises and factory routine test reports will be discussed. After arrival of units in Pakistan, the load testing of the unit will be witnessed at distributor testing facility or any third-party facility (approved by the Purchaser). The associated costs for witnessing of the tests will be borne by the Supplier/Contractor. 		
Extension In Bid Submission Date	Please refer to the Amendment No. 01 to the Tender Notice & Bidding Documents.		
Bid Security submission is allowed in shape of Bank Guarantee from top reputable banks of Pakistan.	Pursuant to clause BDC-18.3, the bidder is required to obtain the bid security from a Scheduled Bank in Pakistan, at the option of the Bidder, in the form of Deposit at Call (CDR, Pay Order or banker's Cheque) or in the form of Bid Guarantee as per format given in the document.		